

## BIS Pacifyre® Fire Protection products

BIS Pacifyre® MK II Fire Sleeve	Tested according to:	Approved in:
	EN 1366-3 BS 476-20 NEN 6069 DIN 4102-11	Austria, Belgium, Czech Republic, Denmark, France, Germany, the Netherlands, Norway, Poland, Sweden, Switzerland, United Kingdom
Tested and approved by:		
BIS Pacifyre® AWM III Fire Collar	Tested according to:	Approved in:
	EN 1366-3 BS 476-20 DIN 4102-11	Austria, Belgium, Czech Republic, Germany, the Netherlands, Poland, Sweden, Switzerland
Tested and approved by:		
BIS Pacifyre® IWM III Fire Strip	Tested according to:	Approved in:
	EN 1366-3 BS 476-20 DIN 4102-11	Austria, Belgium, Czech Republic, Germany, the Netherlands, Poland, Sweden, Switzerland
Tested and approved by:		

## Tangit® Fire Protection products

Product	Tested according to:			Tested and approved by:	
	EN 1366-3	EN 1366-4	EN 998-2		
Tangit® FP 550 2C Fire Protection Foam		✓			        
Tangit® FP 800 Fire Protection Coating		✓			
Tangit® FP 450 Fire Protection Mastic		✓			
Tangit® FP 440 Fire Protection Sealant		✓			
Tangit® FP 430 Fire Protection Acrylic Sealant			✓		
Tangit® FP 410 Fire Protection Silicone			✓		
Tangit® FP 300 Fire Protection Mortar				✓	
Tangit® FP 100 Fire Protection 1C Foam			✓		

The Tangit® FP 550 system is approved in Austria, Belgium, Germany and the Netherlands. For more information please see [www.walraven.com](http://www.walraven.com).