



EC CERTIFICATE

CERTIFICATE OF CONSTANCY OF PERFORMANCE CERTIFICATE No. 2821-CPR-0240


In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product and placed on the market under the name or trademark of

Manufacturer: Walraven Europe B.V.
Address: Industrieweg 5, 3641 RK Mijdrecht
Product: Pacifyre BFC
Places of production: J/001 / E/003
Harmonized requirements: EAD 350454-11-1104, September 2017
Scope of certificate: ETA-17/0285 of 22/03/2021
Product area code: 35, Fire stopping, fire sealing and fire protective products

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the ETA-17/0285 and EAD 350454-00-1104, under system 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 2023-04-17 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Revision: 0
Date of revision: N/A
Issued by UL International (NL) B.V. Notified Body 2821.

Signed: 
Name: Horst Thelen
Head of Notified Body



EC CERTIFICATE

Schedule for certificate No. 2821-CPR-0240

General Information

Product Reference:	Pacifyre BFC
Type:	Penetration Seal – Pipe Collar
Description:	Various sizes of intumescent inlay contained within a steel shell, to be fitted around plastic pipes where they penetrate walls and floors to provide closure in the event of a fire.
Key Performance parameters:	See ETA-17/0285
Identification and intended use	Various sizes of intumescent inlay contained within a steel shell, to be fitted around plastic pipes where they penetrate walls and floors to provide closure in the event of a fire.
CE marking method	Label
UL Project:	4790580833

Limitations on the acceptance or use of the product(s):


Installation instructions	To be used in accordance with the supplier's installation instructions, the Technical Data Sheet and the ETA.
Limitations	See Technical Data Sheet and the ETA

Terms and Conditions:

1. This certificate remains the property of UL International (NL) B.V, herein "UL NL", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL NL.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL NL.
5. This certificate is only valid for placing goods on the EU market.
6. The requirements for the economic operators stipulated in CHAPTER II, Article 4 of the Regulation (EU) 2019/1020 of the European Parliament and of the Council of 20 June 2019

END OF CERTIFICATE

Revision: 0
Date of revision: N/A
Issued by UL International (NL) B.V. Notified Body 2821.

Signed: 
Name: Horst Thelen
Head of Notified Body

Page 2 of 2