

Technische Information Tangit Unilock



DIN-DVGW-Baumusterprüfzertifikat
NV - 5142BP5597

Deutschland

Österreich - Schweiz - South East Europe

Walraven GmbH

Karl-von-Linde-Str. 22

D-95447 Bayreuth

Tel. +49 (0)921 75 60 0

Fax +49 (0)921 75 60 111

info.de@walraven.com

Walraven Group

Mijdrecht (NL) • Tienen (BE) • Bayreuth (DE)

Banbury (GB) • Malmö (SE) • Grenoble (FR)

Barcelona (ES) • Kraków (PL) • Mladá

Boleslav (CZ) • Moscow (RU) • Kyiv (UA)

Detroit (US) • Shanghai (CN) • Dubai (AE)

Budapest (HU)



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NV-5142BP5597

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Henkel AG & Co. KGaA Henkelstrasse 67, D-40589 Düsseldorf
Distributor <i>Vertreiber</i>	Henkel AG & Co. KGaA Henkelstrasse 67, D-40589 Düsseldorf
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for gas and water installations for metallic jointing, non hardening (5142)
Product Description <i>Produktbezeichnung</i>	Non-hardening jointing compound
Model <i>Modell</i>	Tangit UNI-LOCK
Test Reports <i>Prüfberichte</i>	type testing: 19/102/5142/2 from 28.11.2019 (EBI) hygienic test: KA 0386A/15 from 02.12.2015 (TZW)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 751-2 (01.08.1997) DIN 30660 (01.12.1999) UBA KTW (07.10.2008)

Date of Expiry / File No. 26.11.2024 / 19-0393-GNV
Ablaufdatum / Aktenzeichen

70028-04-A-DE

09.01.2020 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
Typ	Technische Daten	Bemerkungen
Tangit UNI-LOCK	class: ARp	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

temperature range: -20...+70 °C (gas), up to +130 °C (hot water), up to +85 °C (drinking water)
pressure range: <= 5 bar (gas), <= 7 bar (hot water), <= 16 bar (drinking water)